

INVITATION TO TENDER
GD/023/19
WATER PUMPS & CHLORINATING SYSTEM

#	UNSPSC variant	Extended description	Unit	Quantity	Price	Total Value
1	40151510.0004	Water pumps Submersible pump 15 HP pipe diameter 4" , head 40meters, output 80cupic meter/hr (special for sewage)	PC	2		
2	40151510.0004	Submersible pump HP75, consisting of the motor & the impeller, pipe dia 4" . Head 250m. Output 60m3/hour.	PC	2		
3	40151510.0004	Water pumps Submersible pump HP60, consisting of the motor & the impeller, pipe dia 4" . Head 250m. Output 40m3/hour.	PC	3		
4	40151510.0004	Submersible pump HP40, consisting of the motor & the impeller, pipe dia 4" . Head 200m. Output 40m3/hour.	PC	4		
5	40151510.0004	Water pumps Submersible Pumps 4" Pipe Diameter consisting of the Motor impeller, Head 150 meters, Output 25 Cubic meter/hr HP 25	PC	4		
6	40151510.0004	Water pumps Horizontal centrifugal pump HP 20, head 50m, output 90m3/hour, Amperage 15Amp.3phase, inlet pipe 4" & outlet pipe 2.5"	PC	4		

No
 1/4/19

INVITATION TO TENDER
GD/023/19
WATER PUMPS & CHLORINATING SYSTEM

#	UNSPSC variant	Extended description	Unit	Quantity	Price	Total Value
7	40151510.0004	Supply complete chlorination system including the following: 1. Complete sodium hypochlorite dosing system comprising of solenoid, adjustable dosing and injection pump of PROMINENT type or equivalent approved type with dosing capacity range 0-4 Liter/hour at 16 bar back pressure. 2. 50 liter polyethylene PE white chlorination tank with built in factory made manual stainless steel mixer in addition to motorized mixer. All associated fittings and accessories required to accommodate and connect the desired tank feeding point through underground 1/2" stainless steel pipe, all according to specifications and instructions by the engineer. 3. Programmable residual chlorine analyzer of Dulcometer type or equivalent approved type, complete with its associated accessories and printer including all required connections so that the system will check the residual chlorine concentration and automatically operate and control the dosing pump to cope with the desired concentration of the residual chlorine at the tank.	PC	4		

INCO TERMS	DAP - Central Warehouse (Bir Hassan - Facing Sportive City)
DELIVERY DATE REQUIRED	15 May 2019

Total for BID	
Discount / Bonus	
Other Charges	

N/A

INVITATION TO TENDER
GD/023/19
WATER PUMPS & CHLORINATING SYSTEM

#	UNSPSC variant	Extended description	Unit	Quantity	Price	Total Value
Vendor Comments						
Vendor Signature and Stamp						

N/A