

Sr.No.	Description	Quantity Required (Nos.)
1	2	3
1	Pressure control valve for CR-201, Flange size= DIN 25, PN 40, Fluid: Gas, Temp. 40 °C, F-F= 152mm with pressure regulator and Electronic positioner	1
2	Degasifier Butterfly control valves, Size 3"x3" #150 Seat material SS316 , F-F 70mm with pressure regulator and Electronic positioner,	1
3	Butterfly water control valve-110, Size 3"x3" #300 Seat material SS316 , F-F 75mm with pressure regulator and Electronic positioner,	1
4	Type Guided control valve, LV- 203, Valve Size 3"x3" #300, Seat material SS316L, F-F 298mm, with pressure regulator and Electronic positioner,	1
5	Globe Type control valve for saturated Steam, Valve Size 2" # 150 (RF), Seat and Stem material SS316 F-F= 225mm, with pressure regulator and Electronic positioner,	1
6	Distilled water type Dead weight tester, with window based CAL software, Range: 0~15000PSI make Fluke/Ametek or Equal.	1

Detailed Specification are attached on separate sheets.

SPECIFICATION OF PRESSURE CONTROL VALVE FOR CR-201

P: 3/9

PCV

QUANTITY= 01 No.

1. PROCESS CONDITIONS AND VALVE SPECIFICATION:

Fluid state:	Gas
Temperature:	40 °C
Specific gravity:	1.19 at 20 °C
Inlet pressure:	10 bar (g)
Outlet pressure:	2 bar (g)
Diff. Pressure:	1 ~ 8 bar (g)
Flow rate:	4 m ³ / min
Critical temperature:	100 °C
Trim material:	SS316L
Flange and valve body:	SS316L
Seat/stem material:	SS316L
Type:	Globe/Plug-Cocks tapered
Actuator type:	Diaphragm
Failure position:	Open (Changeable)
Valve characteristic:	Equal %

2. End Connection:

Flange size:	RF, PN: 40, DIN: 25
Flange To Flange distance:	152mm

3. Air Pressure Regulator with Filter (Integral) and Gauge

Maximum Working Pressure:	12 bar
Set Pressure Range:	0.5 - 8.0 bar
Inlet/Outlet Connection:	¼" NPT (Female)
Body Material:	Die Cast Aluminum
Ambient Temperature:	-5 ~ 60 °C
Filter Element:	Brass
Filter Housing:	Die Cast Aluminum
Drain:	Manual
Pressure Gauge:	0-10 bar

4. Positioner:

Input signal:	4 ~ 20 mA DC
Output:	3 ~ 15 PSI

Specifications for Butterfly Steam control valve

TAG NO. Degasifier Butterfly steam control valve

QUANTITY: 01

P: 4/9

BODY SPECIFICATION

SIZE : 3x3
RATING : ANSI 150

CONN : WAFER (SMOOTH)
TRIM FORM : CONCENTRIC
CHARACT : THROTTLING
BONNET : ST'D (DUST/SAND PROOF)
MO. POS. : S (STANDARD) TYPE
ACTION : AIR TO OPEN / AIR FAIL CLOSE
BODY TRIM : CS
TRIM T. : H. Cr PLATED
BEARING : SUS304 / H. Cr PLATED
SEAT : SUS304
SEAT T. : NONE
PACKING : GLAND - GASKET
PTFE CARBON V1500AC

Flange to Flange Distance: 70mm

Butterfly Thickness: 60mm

ACTUATOR SPECIFICATION

MODEL : PNEUMATIC DIAPHRAGM
SIZE : $\Phi 240$ or Equivalent
ACTION : S. RTN/ DA (PRES. TO OPEN) Air fail Close.
RE.ACT : 2.4(0.6~1.8) Kg/cm²
R. ANGLE : 60 DEG

ACCESSORIES

AIR SET : SS304
Positioner : Electro Pneumatic type, Input 4-20 mA DC

AIR REGULATOR WITH FILTER (INTEGRAL)

MAX. WORKING PRESSURE: 10 Bar
SET PRESSURE RANGE: 0.5 – 6.0 Bar
INLET/ OUTLET CONNECTION: 1/4" NPT
FILTER ELEMENT: BRASS
FILTER BOWL: METALLIC
DRAIN: MANUAL

ACCESSORIES

PRESSURE GAUGE
MOUNTING BRACKET

FLUID SPECIFICATION

FLUID : STEAM

Ambient Temp. 0-55 °C

	UNIT	NORMAL	MAXIMUM
FLOW RATE	Kg/H	1,750.00	2,500.00
P1	KG/cm ²	11.92	12.00
ΔP		0.35	0.35
SHUT OFF	G	12.00	
TEMP.	°C	190.50	200.00

Specifications for Butterfly Water control valve

P: 5/9

TAG NO. Butterfly Water control valve-110

QUANTITY: 01

BODY SPECIFICATION

SIZE : 3x3
RATING : ANSI 300
CONN : WAFER (SMOOTH)
TRIM FORM : CONCENTRIC
CHARACT : THROTTLING
BONNET : ST'D (DUST/SAND PROOF)
MO. POS. : S (STANDARD) TYPE
ACTION : AIR TO Close / AIR FAIL Open
BODY TRIM : CS
TRIM T. : H. Cr PLATED
BEARING : SUS304/ H. Cr PLATED
SEAT : SUS304
PACKING : GLAND - GASKET
PTFE CARBON V1500AC

Flange to Flange Distance: 75mm

Butterfly Thickness: 65mm

ACTUATOR SPECIFICATION

MODEL : PNEUMATIC DIAPHRAGM
SIZE : $\Phi 240$ or Equivalent
ACTION : S. RTN/ DA (PRES. TO Close) Air fail Open.
RE.ACT : 2.4(0.6~1.8) Kg/cm²
R. ANGLE : 60 DEG

ACCESSORIES

AIR SET : SS304
Positioner : Electro Pneumatic type, Input 4-20 mA DC

AIR REGULATOR WITH FILTER (INTEGRAL)

MAX. WORKING PRESSURE: 10 Bar
SET PRESSURE RANGE: 0.5 – 6.0 Bar
INLET/ OUTLET CONNECTION: 1/4" NPT
FILTER ELEMENT: BRASS
FILTER BOWL: METALLIC
DRAIN: MANUAL

ACCESSORIES

PRESSURE GAUGE
MOUNTING BRACKET

FLUID SPECIFICATION

FLUID : Hot Water

Ambient Temp. 0-55 °C

	UNIT	NORMAL	MAXIMUM
FLOW RATE	L/Min	1,750.00	2,500.00
P1	KG/cm ²	28.60	30.00
ΔP		0.35	0.35
SHUT OFF	G	3.00	
TEMP.	°C	75.0	100.00

Specifications for Top Guided control valve

TAG NO. LV- 203

QUANTITY: 01

P: 6/9

BODY SPECIFICATION

SIZE : 3"x 3"
RATING : ANSI 300

CONN : RF (SMOOTH)
TRIM FORM : BALANCE
CHARACT : P.PORT LINEAR
BONNET : ST'D (DUST/SAND PROOF)
MO. POS. : S (STANDARD) TYPE
ACTION : AIR TO OPENE / AIR FAIL CLOSE
BODY TRIM : SUS316L
GUIDE : SUS316L / H. Cr PLATED
SEAT : SUS316L
PACKING : GLAND - GASKET Balance
TV-P.TFE T9090 CAPSEAL

FACE TO FACE
DISTANCE: 298 mm

ACTUATOR SPECIFICATION

MODEL : PNEUMATIC DIAPHRAGM
SIZE : $\Phi 240$ or Equivalent
ACTION : S. RTN/ RA (AIR. TO STEM UP)
RE.ACT : 2.2(0.6~1.1) Kg/cm²
STROKE : 30 mm

ACCESSORIES

AIR SET : PRF 304
Positioner : Electro Pneumatic type, Input 4-20 mA DC

AIR REGULATOR WITH FILTER (INTEGRAL)

MAX. WORKING PRESSURE: 10 Bar
SET PRESSURE RANGE: 0.5 – 6.0 Bar
INLET/ OUTLET CONNECTION: 1/4" NPT
FILTER ELEMENT: BRASS
FILTER BOWL: METALLIC
DRAIN: MANUAL

ACCESSORIES

PRESSURE GAUGE
MOUNTING BRACKET

FLUID SPECIFICATION

FLUID : SOUR WATER

Ambient Temp. 0-55 °C

	UNIT	NORMAL	MAXIMUM
FLOW RATE	L/MIN	1,040.00	1,500.00
P1	KG/cm ²	23.55	30.00
ΔP		1.40	1.40
SHUT OFF	G	8.0	
TEMP.	°C	58.00	100.00
Sp. Gr.		0.978	
	VALVE	CAL.	CAL.
CV VALVE	100	61.32	87.17

P: 2/9

SPECIFICATION OF GLOBE TYPE CONTROL VALVE FOR SATURATED STEAM

Globe Type Control Valve:

Quantity = 01 No

1. PROCESS CONDITIONS AND VALVE SPECIFICATION:

Fluid state:	Saturated Steam
Temperature:	200 °C
Inlet pressure:	8 bar (g)
Outlet pressure:	6 bar (g)
Diff. Pressure:	0.1 ~ 1.9 bar (g)
Bonnet	Extended for high temperature
Critical pressure:	30 bar
Critical temperature:	300 °C
Nominal travel	30mm
Trim material:	SS304
Flange and valve body:	CS
Seat/stem material:	SS304
Type:	Globe
Actuator type:	Diaphragm
Failure position:	Close
Valve characteristic:	Equal %

2. Valve Body:

Plug:	Balanced with graphite Ring
Bonnet:	Extended for high temperature
Leakage class:	Metal Sealing – IV
Plug and Seat:	Material SS304
KVS/CV	40/47

3. End Connection:

Flange size:	RF, 2" #150
Flange to Flange distance	225 mm

4. Air Pressure Regulator with Filter (Integral) and Gauge

Maximum Working Pressure:	12 bar
Set Pressure Range:	0.5 - 8.0 bar
Inlet/Outlet Connection:	¼" NPT (Female)
Body Material:	Die Cast Aluminum
Ambient Temperature:	-5 ~ 60 °C
Filter Element:	Brass

Filter Housing:

Die Cast Aluminum

Drain:

Manual

Pressure Gauge:

0-10 bar

P: 8/9

5. Positioner:

Input signal:

4 ~ 20 mA DC

Output:

3 ~ 15 PSI

- Note:**
1. All wetted part must compliance with NACE MR-01-03
 2. Technical literature, maintenance & installation manuals are required in English.
 3. On-site inspection at Manufacturer premises should be included in quotation.
 5. Recommended maintenance schedule [Preventive (PM), Predictive (PDM,)] by vendor in English is required.
 6. Material test certificate, pressure test certificate of valve body at 40 Bar and warranty Certificate is required.

P: 9/9

SPECIFICATION OF DISTILLED WATER TYPE DEAD WEIGHT TESTER .

N ^o QUANTITY:	01 No.
Range:	0 ~15000 PSI
Accuracy:	±0.015% of reading
Material of Construction:	Standard Weight material: Series-3 Non-Magnetic austenitic stain less steel
Weight density:	7.8 g/cm ³
Piston Material:	Tungsten carbide with nickel binder, Density 15g/cm ³
Cylinder material:	Hardened martensitic steel tungsten carbide
Thermal Coefficient of Expansion:	Cylinder 16.5ppm/ ⁰ C (Water above 500PSI, 35Bar, 11ppm/ ⁰ C).
Reservoir Volume:	150 CC
Pump Displacement:	4.7 CC / Stroke
O-Ring Seal material:	BUNNA N
Operating Fluid:	Distilled water
Press. CAL Software:	Window based software program that allows uses to easily apply all accessory correction to enhance the dead weight tester performance.

Note:

1. Technical literature, maintenance & installation manuals are required in English.
2. On-site inspection at Manufacturer premises should be included in quotation.
3. Recommended maintenance schedule [Preventive (PM), Predictive (PDM,)] by vendor in English is required.
4. Pressure test certificate and warranty Certificate is required.