

Sr. No	Description/Specification/Cat/Part No. of Scientific/Technical/Administrative Stores	Qty. Required
1	Differential Pressure Gauges Range: -400 to 0 mmWG	10 Nos.
2	Differential Pressure Gauges Range: 0 to 100 mmWG	150 Nos.
3	Differential Pressure Gauges Range: -50 to 0 mmWG	100 Nos.
4	Pressure Gauges Range: 0 to 10 Bar	10 Nos.
5	Pressure Gauges Range: -1 to 0 Bar	6 Nos.
6	Pressure Gauges Range: -0.6 to 0 Bar	4 Nos.
7	Pressure Gauges Range: 0 to 20 Bar	2 Nos.

Customer _____ Equipment: <u>Differential Pressure Gauges</u> Plant _____ Requisition No. _____ Contract No. _____					PROJECT: _____					
					No.	By	Date	Revision	Sheet	
								A	Made By	Date
									Chek'd by	Date
									Appr. By	Date

<p align="center">TYPE</p> <p align="center">MODEL AND CASE</p> <p>1. Indicator: Differential Pressure.</p> <p>2. : Standard</p> <p>3. Enclosure: <u>General Purpose</u></p> <p>4. Material: <u>All Stainless Steel</u></p> <p>5. Ring: Front</p> <p>6. Indicator: Circular 150 mm</p> <p>7. Dial: White, Black Figures</p> <p>8. Scale Range: Standard Others: <u>See List</u></p> <p align="center">PRESSURE ELEMENT</p> <p>9. Type: Bellows</p> <p>10. Material: S.St.</p> <p align="center">MECHANISM</p> <p>11. Standard</p> <p>12. Material: S.ST.</p>	<p align="center">PROCESS CONNECTION</p> <p>13. Bottom</p> <p>14. Connection: 1/4 " NPT (Female)</p> <p>15. Thread: Internal (Female)</p> <p>16. Flange Material: S.St.</p> <p align="center">OPTION AND ACCESSORIES</p> <p>17. seal: NA</p> <p>18. Mounting: NA</p> <p align="center">SPECIAL PROTECTION</p> <p>19. All parts in contact with process <u>S.ST.</u></p> <p>20. External nuts and screw <u>S.ST.</u> Case <u>S.ST.</u></p>
--	--

Sr. No.	Description	Range			Service Conditions				Graduation	Qty Required	Remarks
		From	To	Unit	Fluid	Operating Pressure	Over Pressure	Temp C°			
1	Differential Pressure Gauges	-400	0	mm WG	Vacuum Air	-250	-450	50	mm WG	10 Nos	
2	Differential Pressure Gauges	0	100	mm WG	Vacuum Air	-250	-450	50	mm WG	150 Nos	
3	Differential Pressure Gauges	-50	0	mm WG	Vacuum Air	-25	-100	50	mm WG	100 Nos	
Total Differential Pressure Gauges										260	

Customer _____ Equipment: <u>Pressure Gauges</u> Plant _____ Requisition No. _____ Contract No. _____					PROJECT: _____					
					No.	By	Date	Revision	Sheet	
								A	Made By	Date
									Chek'd by	Date
									Appr. By	Date

<p align="center">TYPE</p> <p align="center">MODEL AND CASE</p> <p>1. Indicator: Pressure.</p> <p>2. : Standard</p> <p>3. Enclosure: <u>General Purpose</u></p> <p>4. Material: <u>All Stainless Steel</u></p> <p>5. Ring: Front</p> <p>6. Indicator: Circular 150</p> <p>7. Dial: White, Black Figures</p> <p>8. Scale Range: Standard Others: <u>See List</u></p> <p align="center">PRESSURE ELEMENT</p> <p>9. Type: <u>Bourdon Tube</u></p> <p>10. Material: S.S.</p> <p align="center">MECHANISM</p> <p>11. Standard</p> <p>12. Material: S.ST.</p>	<p align="center">PROCESS CONNECTION</p> <p>13. Bottom</p> <p>14. Connection: 1/2 " NPT (Male)</p> <p>15. Thread: External (Male)</p> <p>16. Flange Material: S.St.</p> <p align="center">OPTION AND ACCESSORIES</p> <p>17. seal: NA</p> <p>18. Mounting: NA</p> <p align="center">SPECIAL PROTECTION</p> <p>19. All parts in contact with process <u>S.ST.</u></p> <p>20. External nuts and screw <u>S.ST.</u> Case <u>S.ST.</u></p>
---	--

Sr. No.	Description	Range			Service Conditions				Graduation	Qty Required	Remarks
		From	To	Unit	Fluid	Operating Pressure	Over Pressure	Temp C°			
1	Pressure Gauges	0	10	Bar	Chilled Water/Steam	8	12	5 ~ 150	Bar	10 Nos	
1	Pressure Gauges	-1	0	Bar	Vacuum Air	-0.8	-1	50	Bar	6 Nos	
2	Pressure Gauges	-0.6	0	Bar	Vacuum Air	-0.5	-1	50	Bar	4 Nos	
Total Pressure Gauges										20	

